Manufacturer: RWC, Horton Road, West Drayton, UB7 8JL +44 (0) 1895 449233
Product: Floreg Isolating Valve and Strainer
Product code: SERV970000 (15mm),
Contact:
Email:
Website: www.reliancevalves.com

Description: Reliance Valves Floreg Isolating Valve and strainer must be WRAS and KIWA Reg 4 approved. The valve must supply 4 to 15LPM and have a 4LPM set flow rate. Maximum pressure must be up to 16.0 bar and maximum water temperature must be up to 85°C. Connections must be compression and compatible with copper pipe. The nickel plated valves must have a plastic identity cap to reveal the amount of flow regulation.